



## MEDIA INFORMATION / PUBLIC INFORMATION WORKSHEET

Please email to PIO Larry Gallegos at [lagallegos@bernco.gov](mailto:lagallegos@bernco.gov) (505) 228-6668

1. Date/Incident number	11/30/2015 - 2015-017371
2. Incident Address	2400 Bridge Blvd
3. Area of County	South Valley
4. Mutual Aid request/given	None
5. Reported by:	Unknown/Passerby
6. Fire Condition/Alarms (working fire, 2 <sup>nd</sup> alarm)	Working fire, 1 <sup>st</sup> alarm plus 1 additional unit
7. Size & Type of Structure/Incident (apt/residential home/ bldg)	Approx 800 sq ft single story building used as a residence, also building was undergoing a remodel
8. Number of Personnel Responded (Units and FFs)	E33, E34, TR38, R32, R33, R34, E32, BAT8, BAT6, FMO 33, OPSCHF (3) (3) (3) (2) (2) (2) (3) (1) (1) (1) (1) = 21
9. Time Dispatched/1 <sup>st</sup> Unit Arrival time	Dispatched – 18:01 1 <sup>st</sup> unit arrived – 18:07
10. Brief description of what 1 <sup>st</sup> unit on the scene saw.	Moderate smoke coming from the eaves of the roof with flames through the gable hole on the roof.
11. Total time to bring fire under control	28 mins
12. Anyone inside at the time of the fire. If yes, how many	No one inside at the time of the fire
13. How was family alerted? (smoke detector, neighbors)	No detection systems in the structure
14. Injuries? If yes, include age, gender, transport info & injuries sustained.	None
15. Fire Origin? Was it contained to origin?	Fire was contained to an approx. 10 ft area of the roof
16. Spread through %	5-10% of the roof – no fire damage inside the rest of the structure
17. Smoke Damage (light or heavy smoke damage throughout)	Very light smoke damage in the room just below the fire, moderate water damage in the room below
18. Cause (determined/undetermined -->accident,natural,incendiary)	Accidental – improper stovepipe installation
19. Estimated Damages (structural, contents/vehicle)	\$5000-8000 – structural
20. Assisting Agencies like Red Cross, # of displaced?	None
21. Contributing factors such as wind or location	Heat source left unattended – (wood burning stove)
22. Additional information (rescues, FF injuries and so on)	No FF injuries noted
23. On Scene POC	None scene POC
24. Community Risk Reduction Message	Proper installation of stovepipes for wood stove (double wall) and never leave a fire unattended even in a wood stove or fire place.
25. Additional Information	None